



This letter enfolded 1 page.

tgm

Staatliche Versuchsanstalt

Elektrotechnik und Elektronik

FEDERAL INSTITUTE OF TECHNOLOGY
ELECTRICAL AND
ELECTRONIC ENGINEERING

Company
Tehnoplast d.o.o.

c/o Mr. Nebojša Zubović

Zdravka Jekica 119
Srbija - 22305 Stari Banovic

your sign

your message from

our sign
DL

official in charge
Ing. D. Litzka

date
2011-10-19

re: pillar terminal N/7, PE/7, N/12, PE/12, N/15, PE/15
order number: TGM-VA EE 33855

As ordered we carried out the tests according to:
ÖVE/ÖNORM EN 60998-1: 2005-05-01
ÖVE/ÖNORM EN 60998-2-1: 2005-05-01
with the pillar terminal:

type: N/7, PE/7, N/12, PE/12, N/15, PE/15
manufacturer: Tehnoplast d.o.o.
insulating material: Polyamid PA 6
ratings: AC / DC 250 V; 16 mm²

The pillar terminal type: N/7, PE/7, N/12, PE/12, N/15 and PE/15 passed the tests according to ÖVE/ÖNORM EN 60998-1: 2005-05-01 and ÖVE/ÖNORM EN 60998-2-1: 2005-05-01 (see Test reports: TGM-VA EE 33855 SFT with 11 pages).

We request to transfer the accumulated costs to our account according to the attached invoice.

with best regards

Dipl.-Ing. Karl Reischer
Principal



Prof.Dipl.-Ing.Dr.techn.W.Nitsche
Head of Department